

Form II

[See Regulation 7]

Permission / Renewal of Permission

No. BEE/DT/ReNew/2020

Bureau of Energy Efficiency

New Delhi, Dated - 07-07-2020 21:00:49

To,

**MR SHYAM SUNDER BAJAJ [Partner]**

**Shree Transformers**

**F - 654, ROAD NO 9F-2**

**Vishwakarma Industrial Area, Jaipur JAIPUR -302013 Rajasthan**

**Mb:- 9829071279 Fax no:- 0141- 2460085**

1. Pursuant to the provisions of regulation 7 of the Bureau of Energy Efficiency (Particulars and Manner of their display on Labels of Distribution Transformer) Regulations, 2009, the BUREAU hereby permits you to affix Label as per details of approvals set out in the Annexure.
2. This permission is subject to-
  - (a) the star level displayed on the label of the Distribution Transformer shall conform to energy consumption standards for Distribution Transformer notified under clause (a) of section 14 of the Act ;
  - (b) the label shall be affixed only on such model of Distribution Transformer for which permission has been granted;
  - (c) the label shall be printed and affixed on the Distribution Transformer at the cost of the permittee;
  - (d) the permittee shall ensure that the star level displayed on the label of Distribution Transformer shall be maintained at all time;
  - (e) the permittee shall pay the label fee of rupees 100 per label;
  - (f) the permittee shall furnish to the Bureau a statement containing details of production of labelled equipment and the accrued labelling fee due for each quarter within the following month of the close of each quarter of the financial year. The same details shall be furnished to the Bureau also through automated system.
  - (g) The same details shall be furnished to the Bureau also through automated system.
  - (h) the permittee shall make available such other details of Distribution Transformer as and when sought by the Bureau for which the permission has been granted.
3. This permission shall be valid for from **12 January 2018** to **31 December 2022** and may be renewed as prescribed. You shall not withdraw the Distribution Transformer from the market during the validity period of permission except with the prior approval of the Bureau.
4. The unique label series code assigned by Bureau of Energy Efficiency for the equipment is **BEE/SHT/03/0410/11** and should appear on the label as per the approved design.
5. Where the star level plans on review is modified by the Bureau and the star level of the Distribution Transformer stand modified, You shall seek the permission a fresh.
6. Signed, sealed and dated this **7** day of **7** month **2020** year

For Secretary

**BUREAU OF ENERGY EFFICIENCY**

This is a digitally signed document, not requiring signature.

स्वहित एवं राष्ट्रहित में ऊर्जा बचाएँ Save Energy for Benefit of Self and Nation

Annexure

[See para 1 of Form II]

Details of Approvals

1. Details of the Equipment

Equipment / Type	Distribution Transformer / Oil filled naturally cooled
Make /Manufacturer/ Importer	SHREE / Manufacturer
Model name/ Number	SHREE/63/L2/1S
Transformer Capacity KVA	63 KVA
Voltage	Upto 11 KV
Year of manufacturing	2017
Total losses at 50% loading - Watts	340
Total losses at 100% loading - Watts	1140

S/No	Applica tion ID	Model No.	Capacit y Rating( KVA)	Measured Values				Rated Values		Recom mende d Star Label
				Total Loss at 50% Loading (in Watts)	Total Loss at 100% Loading (in Watts)	No Load Loss (in Watts)	Load Loss(in Watts)	Total Loss at 50% Loading (in Watts)	Total Loss at 100% Loading (in Watts)	
1	90507	SHREE/6 3/L2/1S	63	318	887	129	758	340	1140	1


2. Label Details

Equipment	Distribution Transformer
Type	Oil filled naturally cooled
Make /Manufacturer/ Importer	SHREE / Manufacturer
Model name/ Number	SHREE/63/L2/1S
Transformer Capacity KVA	63 KVA
Voltage	Upto 11 KV
Year of manufacturing	2017
Star level	1
Total losses at 50% loading - Watts	340
Total losses at 100% loading - Watts	1140
Unique label series code	<b>BEE/SHT/03/0410/11</b>

3. Approved Specimen of printed label to be affixed on the Distribution Transformer

This is a digitally signed document, not requiring signature.

स्वहित एवं राष्ट्रहित में ऊर्जा बचाएँ Save Energy for Benefit of Self and Nation



The unique label series code provided in the letter has to be mentioned in the label affixed on the Distribution Transformer .

4. The label design, size , colour scheme, material to be used for the label and the content of the label and colour scheme of the Bureaus' logo shall be as specified in the schedule to the Bureau of Energy Efficiency (Particulars and Manner of their Display on Labels of Distribution Transformer) Regulations, 2009.

Date:07-07-2020

Name: SAMEER PANDITA

Designation: Director

For and on behalf of: Secretary

(Name of the firm)

SEAL OF FIRM

समीर पांडिता/SAMEER PANDITA  
निदेशक/Director  
ऊर्जा दक्षता ब्यूरो  
Bureau of Energy Efficiency  
नई दिल्ली/New Delhi-110066

This is a digitally signed document, not requiring signature.

स्वहित एवं राष्ट्रहित में ऊर्जा बचाएँ Save Energy for Benefit of Self and Nation